

Emergency Lighting Test Kit

Key Operated Emergency Lighting Testing System

- Microcontroller based
- ON-delay
- 10 time ranges(1s,10s,1m,10m,1h,10h,1d,10d,ON,OFF)
- Repetition accuracy<0.2%
- LED indication for power supply and relay status
- 1 Module Din-rail mounting



SPECIFICATIONS

| | |
|---------------------|---------------------------------------|
| Supply voltage | AC 230V |
| | AC/DC 12-240V |
| | AC/DC 24-240V |
| Rated frequency | 50/60Hz |
| Time range | 0.1s - 10days |
| Setting accuracy | <5% |
| Repetition accuracy | <0.2% |
| Output contacts | 1 C/O |
| | 2 C/O |
| Current rating | 8A/AC1 |
| Contacts capacity | AC-15: 2A |
| Insulation voltage | 250V |
| Protection degree | IP20 |
| Pollution degree | 3 |
| Electrical life | 105 |
| Mechanical life | 106 |
| Altitude | ≤2000m |
| Ambient temperature | -5°C ~ +40°C |
| Storage temperature | -10°C ~ +50°C |
| Wire size | 0.5mm ² - 1mm ² |
| Torque | 0.5Nm |
| Mounting | TH-35 DIN-Rail |

ORDERING INFORMATION

| | |
|-------------|-----------------------------|
| Barcode | 0726436717113 |
| Description | Emergency Lighting Test Kit |
| Item Code | AL8EM-LTKKO |

PRODUCT & PACKAGE

| | |
|-------------------------------|------------------------|
| Product (mm) Weight (kg) | 130 x 122 x 85 (0.4kg) |
| Outer Carton (cm) Weight (kg) | 34 x 33 x 34.6 (8.5kg) |
| Outer Carton Quantity | 20 |

COMPLIANCE

| | |
|-----------|--------------|
| Standards | AS/NZS 60598 |
| | AS/NZS 61347 |
| | AS CISPR 15 |
| | AS/NZS 2293 |

WARRANTY

| | |
|----------------------|-----------|
| Replacement Warranty | 12 Months |
| Labour not included | |

LINE DRAWINGS

AL8EM-ECLIPSE

